



Purchasing Department

209 Water Street
Johnson City, TN 37601
(423) 975-2716

ADDENDUM

TO: All Prospective Vendors

FROM: Debbie Dillon
Director of Purchasing

SUBJECT: Addendum No.1 – ITB #6043
Wrought Iron Fencing Project

DATE: June 6, 2016

Consider this addendum an integral part of the above referenced solicitation:

Please note the following:

Fence posts are to be core drilled into concrete and plate is attached to the surface, no welding of the plate is required.

Gate posts are to be mounted onto the brick columns, attached to brackets that will be installed by the City

All other specifications remain the same. **Vendor to acknowledge receipt of this addendum by initialing and returning the addendum notice with the return solicitation package or via email if it has already been submitted.**
Any questions regarding addendum submittal please contact this office.

/vh