

**ADDENDUM NUMBER ONE**

October 3, 2016

The original Project Manual and Drawings, dated September 14, 2016, for the above project are amended as noted in this Addendum. Receipt of this Addendum shall be acknowledged on the Bid Form on which the Contractor submits his bid.

This Addendum consists of one (1) page and the attachments noted herein.



GENERAL:

ADD 1-1 Note that the City of Johnson City Plans Review Fee has been paid. Contractor shall, however, pay all required permitting fees.

SPECIFICATIONS:

ADD 1-2 Refer to Specifications Section 00 21 13 – Instructions to Bidders, and to paragraph titled “Bonds”. Roof Bond is not required this project.

ADD 1-3 Refer to Specifications Section 08 36 13 – Upward Acting Sectional Doors and to 2.01. CHI Overhead Door Series shall be 3220 in lieu of 3240. Additionally, subject to full compliance with the specifications, HAAS Door (Model C2011) is an approved manufacturer.

ADD 1-4 Refer to Specifications Section 10 44 16 – Portable Fire Extinguishers and Accessories. Four (4) extinguishers will be required; mounting locations will be directed by the Architect prior to installation.

DRAWINGS:

ADD 1-5 Simpson Strong-Tie H-4 Hurricane Ties shall be installed each end of all new and existing wood trusses.

ADD 1-6 New top-of-wall wood blocking to which trusses are attached shall be attached to masonry with 3/8” diameter expansion anchors with 1” diameter washer set into masonry head joints at approximately 16” o.c.

ADD 1-7 Refer to Drawing P-1 and to hose connection at building front wall. Remove existing hose fill connection on front face of building. Install new Series 25 Woodford freezeless 3/4” wall hydrant, complete with vacuum breaker, in this same location and connect to new interior water piping. Patch wall as required.

ADD 1-8 Refer to Drawing A2 and to Work Room 101, Clean-up 102, Electrical 103, and Office 104. Remove existing vinyl composition tile and wood base, and existing glue, and prepare existing concrete slab for new vinyl composition tile.

END OF ADDENDUM NUMBER ONE

  
\_\_\_\_\_  
(Signature)

Debra Dillon, Director, CPPO, CPPB  
\_\_\_\_\_  
(Printed name and title)