

(ITB NO. 5644)
RE-ROOFING OF THE
OLD PENNEY'S BUILDING
(PORTION OF THE HANDS-ON REGIONAL MUSEUM)
315 EAST MAIN STREET
JOHNSON CITY, TENNESSEE

BEESON, LUSK & STREET, INC.
207 EAST MAIN STREET, SUITE 3C
P.O. BOX 1909 ZIP CODE 37605-1909
JOHNSON CITY, TN 37604-5749
423-928-1175 EMAIL: bls@blsarch.com



OCTOBER 18, 2012

ADDENDUM NO. 1

1. Refer to Specification Section 07520, Fully Adhered Roofing System, Paragraph 1.01.A. Roofing membrane is to be non-reinforced. Omit reference to 'reinforced'.
2. Refer to Specification Section 07520, Fully Adhered Roofing System, Paragraph 1.05.B. Omit reference to two (2) layers of 1-1/2" polyiso board. Refer to Paragraph 2.03, of this same section, and the Drawings for information in regard to insulation. Omit reference to wood deck. Existing deck is concrete.
3. Refer to Drawing Sheet A-1, Roof Plan Note No. 6. Omit reference to steel stairs needing to be painted.
4. Refer to Drawing Sheet A-1, and specifically the right hand (East) wall of the roof to be replaced. An overflow scupper (OSC) is noted at the South end of this wall. Omit reference to this OSC. It is not required at this location.
5. Refer to Drawing Sheet A-1, and specifically the large existing exhaust fan ductwork at the right hand corner of the plan. This piece of ductwork is not to be painted.

END OF ADDENDUM NO. 1